



**Legend**

- Sitewide Groundwater Sample Locations

Connecticut Remediation Standard Regulations Groundwater Criteria

	SWACUTE	SWCHRONIC	SWPC
Hexavalent Chromium	1.1 mg/L	0.05 mg/L	0.11 mg/L

Figure 8.2-29  
Hexavalent Chromium Distribution in Groundwater  
Elevation - 25 ft, MSL  
Remedial Investigation Report  
Stratford Army Engine Plant  
Stratford, Connecticut  
MACTEC Engineering and Consulting